



Daily Pool Log Template

Complete

Score	35%	Flagged items	1	Actions	0
Pool Name	Outdoor Olympic Pool				
Month	February				
Year	2023				
Pool Operator/Pool Manager	Johan Johnston				
Location	5178 Arvinels Ave, San Diego, CA 92117, USA (32.8398998, -117.1753997)				
Conducted on	03.02.2023 08:00 PST				

Flagged items

1 flagged

Daily Pool Log / Pool Log / Pool Log 1

• pH

6.8

Daily Pool Log

1 flagged, 35%

Pool Log

1 flagged, 35%

Pool Log 1

1 flagged, 35%

• Date and Time

03.02.2023 08:00 PST

• Temperature (F)

76

• Water Clarity

Clear

• Disinfectant

Stabilized Chlorine (Tablets or granules containing Dichlor or Trichlor)

Free Chlorine (ppm)

4
From 0 to 11

• Combined Chlorine (ppm)

0.2
From 0 to 1

Conduct superchlorination by adding ten times the combined chlorine ppm

• Total Chlorine (Free Chlorine + Combined Chlorine)

4.2

• pH

6.8

Raise the pH, add soda ash (sodium carbonate)

• Flow GPM

73

• Bather Load

8

Sign Off

Comments

Added soda ash and pH is now 7.6

Based on the photo attached, we're using a new tool in collecting pool water samples to check the pH level.



Photo 1

Name and Signature

Johan Johnston

Appendix



Photo 1