



# Septic Tank Inspection Checklist

23 May 2023 / Gravity Drainfield

Complete

Flagged items	6	Actions	2
System Type	Gravity Drainfield		
Address	Farmington, WA 99128, USA (47.0893399, -117.0440605)		
Inspector	Jairus Clare		
Conducted on	23.05.2023 08:50 PST		

**Flagged items & Actions**

6 flagged, 2 actions

**Flagged items**

6 flagged, 1 action

Septic Tank Inspection Checklist / During the Inspection / Septic Tank

**Where is the liquid level in the tank?**

Below Outlet Pipe



Photo 3

To Do | Priority High | Due 30.05.2023 08:54 PST | Created by SafetyCulture Staff

**Repair septic tank**

The tank may be leaking

Septic Tank Inspection Checklist / During the Inspection / Septic Tank

**Does the scum layer look like living, healthy soil?**

No

Septic Tank Inspection Checklist / During the Inspection / Septic Tank

**Can you clearly see baffles above the scum layer?**

No



Photo 4

Septic Tank Inspection Checklist / During the Inspection / Septic Tank

**Are baffles free of clogs and leaks around the seals? (If concrete—Is it intact and not corroded?)**

No



Photo 5

Septic Tank Inspection Checklist / During the Inspection / Septic Tank

**Did you clean the outlet baffle filter?**

No

Septic Tank Inspection Checklist / During the Inspection / Gravity Drainfield Septic System

**Are there no mushy or swampy areas or surfacing effluent (liquid wastewater)?**

No

**Other actions**

1 action

Septic Tank Inspection Checklist / During the Inspection / Septic Tank

**Are the risers watertight with no visible leaks?**

Not Present

To Do | Priority Medium | Due 30.05.2023 08:53 PST | Created by SafetyCulture Staff

Consider installing risers

Additional safety measure

## Before the Inspection

Take/attach photo(s) of as-built drawing



Photo 1

Date of Last Septic Tank Inspection

04.04.2022

Date of Last Septic Tank Pumping

25.11.2022

Have there been any repairs on the septic tank?

No

## During the Inspection

6 flagged, 2 actions

Are you inspecting with someone—who marks off this checklist as you go and calls a professional if you encounter problems?

Yes

Are you wearing protective clothing (e.g. rubber gloves and eye protection)?

Yes

Have you assembled the tools and materials needed for the inspection?

Yes



Photo 2

Have you reviewed the safety rules (e.g. fall and trip hazards)?

Yes

## Septic Tank

5 flagged, 2 actions

Are the risers watertight with no visible leaks?

Not Present

To Do | Priority Medium | Due 30.05.2023 08:53 PST | Created by SafetyCulture Staff

Consider installing risers  
Additional safety measure

Are the risers free of cracks or visible damage?

Not Present

Is the tank free of strong, overpowering odor?

Yes

Where is the liquid level in the tank?

Below Outlet Pipe



Photo 3

To Do | Priority High | Due 30.05.2023 08:54 PST | Created by SafetyCulture Staff

Repair septic tank

The tank may be leaking

Does the scum layer look like living, healthy soil?

No

Is the scum layer well below lid opening?

Yes

Can you clearly see baffles above the scum layer?

No



Photo 4

Are baffles free of clogs and leaks around the seals? (If concrete—Is it intact and not corroded?)

No



Photo 5

Did you clean the outlet baffle filter?

No

## Scum and Sludge Measurements

Scum

Inlet scum

Outlet scum

Total scum height (in inches)

Sludge

Inlet sludge

Outlet sludge

Total sludge height (in inches)

Does your tank need pumping?

System Type

Gravity Drainfield

Gravity Drainfield Septic System

1 flagged

Are there no strong odors?

Yes

Are there no mushy or swampy areas or surfacing effluent (liquid wastewater)?

No

Is there no standing water inside the inspection port(s)?

Not Present

Does the system have a distribution box?

Yes

Is it accessible?

Yes

Is the distribution box free of solid waste, scum, and clogs?

Yes



Photo 6

Is the distribution box free from cracks and leaks?

Yes

Does the effluent appear to be flowing evenly into all drain pipes?

Yes

## After the Inspection

Are all openings covered and lids secured?

Yes

Are all tools washed and sanitized?

Yes

Are septic system maintenance records updated?

Yes

## Completion

Additional Comments

Repairs needed, refer to assigned actions

**Inspector Name & Signature**



Jairus Clare  
23.05.2023 08:57 PST

---

**Other Inspector**

---

**Other Inspector 1**

---

**Name & Signature**



Vincent Fuentes  
23.05.2023 08:57 PST

---

