



Smoke Detector Inspection Checklist

29 May 2023 / Mark Windham

Complete

Score	66.67%	Flagged items	0	Actions	0
Location	5 Whiting Ave, Dedham, MA 02026, USA				
Conducted on	29.05.2023 10:30 PST				
Prepared by	Mark Windham				

Smoke Detector Inspection 66.67%

Room/Unit 50%

Room/Unit 1 66.67%

Location Pantry

Serial Number 6912BCKDLA

Is the smoke detector securely fastened to the wall or ceiling? Yes

Does the smoke detector show no evidence of physical damage, paint application, or excessive grease and dirt accumulations? Yes

What is the expiration date of the smoke detector's battery? 29.05.2023 10:30 PST

Does the battery need replacement? No

Room/Unit 2 33.33%

Location Office Room 1

Serial Number 7456APGDLF

Is the smoke detector securely fastened to the wall or ceiling? Yes

Does the smoke detector show no evidence of physical damage, paint application, or excessive grease and dirt accumulations? No

The unit is already yellowish



Photo 1

What is the expiration date of the smoke detector's battery? 30.04.2024 00:00 PST

Does the battery need replacement? No

Testing of Detectors 100%

Have all Smoke Detectors in the installation been tested? Yes

How many Smoke Detectors were tested? 2

Have all detectors that were tested passed the operational test procedures?

Yes

How many Smoke Detectors were tested?

2

Have all Smoke Detectors that failed the tests been replaced?

N/A

Is any further action required to meet compliance of these installations

Yes

Next Due Date for Smoke Detector Inspection

Your next test is due on:

31.03.2024

Confirmation

Further to the installation of smoke detectors at the listed address above, this compliance certificate is to confirm the installation of smoke detectors and state their installation and operational compliance, and that they have been hard wired to the electrical system in accordance with the above standards.

Full Name and Signature of Inspector



Mark Windham
29.05.2023 10:38 PST

Media summary



Photo 1