



Smoke Alarm Maintenance Checklist

Complete

Score	5 / 7 (71.43%)	Flagged items	0	Actions	0
-------	----------------	---------------	---	---------	---

Location conducted

3407 Winona Ave, Burbank, CA
91504, USA
(34.1997614, -118.3476102)

Conducted on

27.03.2025

Name of inspector

Jayce Kohler

Photos

Upload photo of smoke alarm/s

newly bought smoke alarm.



Photo 1

Audit

5 / 7 (71.43%)

Has the battery been replaced?

Yes

Is there dust buildup in the smoke alarm?

No

Did you test the battery by pressing the test button?

Yes

Decibel Test: How loud is the alarm?

Safe

Are all your smoke alarms properly interconnected?

No

One smoke alarm at the ground floor didn't go off. We called an electrician to resolve this ASAP!

Have you replaced the smoke alarm? (Replace if it's 10 years old or older.)

Yes

Are smoke alarms correctly installed and in all required areas? (<https://www.nfpa.org/education-and-research/home-fire-safety/smoke-alarms/installing-and-maintaining-smoke-alarms>)

Yes

Picture of installation



Photo 2

Observations and recommendations for any actions to be taken

The following observations and recommendations are made:

Everything is good. Just be sure to repair that one at the ground floor.

Sign off

All smoke alarms are in working condition; and have been tested accordingly to the manufacturer's instructions?

Next smoke alarm check is

27.03.2026

All smoke alarm must be tested according to the manufacturer's instruction at least once every 12 months.

Completed by:

Forrest Weimann

Sign:

Forrest Weimann
27.03.2025 08:59 PST

Media summary



Photo 1



Photo 2